



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 9/22/09

Code 53.20-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title P2603.2.1 Protection against physical damage		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>P2603.2.1 Protection against physical damage. In concealed locations, where piping, other than cast-iron or galvanized steel, is installed through holes or notches in studs, joists, rafters or similar members less than 4-1/2 <u>1 1/4</u> inches (38 <u>31</u> mm) from the nearest edge of the member, the pipe shall be protected by steel shield plates. Such shield plates shall have a thickness of not less than 0.0575 inch (1.463 mm) (No. 16 Gage). Such plates shall cover the area of the pipe where the member is notched or bored, and shall extend a minimum of 2 inches (51 mm) above sole plates and below top plates.</p>		
REASON		
<p>This proposed amendment, from the current code, changes the distance that is allowed from the edge of a framing member to a soft plumbing pipe where a nail strike plate is required. The distance is changed to correspond to the distance required in the electrical chapters</p> <p>Fiscal impact: no increase to the cost of construction, current amendment language.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		